

**STATE OF NEW JERSEY
BOARD OF PUBLIC UTILITIES**

**In the Matter of the Provision of Basic Generation Service for the Period Beginning
June 1, 2026**

BPU Docket No. ER25040190

RESPONSE TO DISCOVERY REQUEST

RCR-BGS-61. In reference to the to the EDCs' Proposal for Basic Generation Service Requirements to be Procured Effective June 1, 2026, dated July 1, 2025 at page 14:

- a. please provide the number and load requirements (capacity and energy) of data center customers within the Company's service territory for the past five years;
- b. please provide the number and load requirements (capacity and energy) of data center customers under BGS-CIEP rates within the Company's service territory for the past five years; and
- c. please provide the projected number and load requirements (capacity and energy) of data center customers within the Company's service territory for the next three years.

Response:

- a. See the Table below, which provides the number and load requirements of data center customers within the Company's service territory:

	2020	2021	2022	2023	2024
Number of Customers	9	9	9	9	10
Annual Energy billed (mWh)	70,723	71,746	71,106	69,706	76,602
Maximun Demand billed (mW)	13	14	14	13	19

- b. See the Table below, which provides the number and load requirements of data center customers under BGS-CIEP rates for at least one month during the past five years:

	2020	2021	2022	2023	2024
Number of Customers	3	2	2	2	2
Annual Energy billed (mWh)	13,173	11,610	12,497	10,952	13,049
Maximun Demand billed (mW)	4	3	3	4	8

- c. The Company has 6 requests in queue for detailed load studies for prospective data centers. As of this date, only one customer has signed a construction agreement.

Attachment(s): N/A.