

**In the Matter of the Provision of Basic Generation Service
for the Period Beginning June 1, 2026
BPU Docket No. ER25040190**

DIVISION OF RATE COUNSEL DISCOVERY REQUESTS

Response Date: August 4, 2025

Respondent: Michael O'Connor – Manager New Business

RCR-BGS-79.

In reference to the to the EDCs' Proposal for Basic Generation Service Requirements to be Procured Effective June 1, 2026, dated July 1, 2025 at page 14:

- a. please provide the number and load requirements (capacity and energy) of data center customers within the Company's service territory for the past five years;
- b. please provide the number and load requirements (capacity and energy) of data center customers under BGS-CIEP rates within the Company's service territory for the past five years.
- c. please provide the projected number and load requirements (capacity and energy) of data center customers within the Company's service territory for the next three years.

Response:

- a. RECO has two data centers in its service territory. One has a demand of 11424 KW and typical monthly energy consumption of 8,233,764.00 kWh. The other has a demand of 4895 kW and a typical monthly energy consumption of 3,068,987.04 kWh.
- b. Neither of these data centers are BGS-CIEP customers of RECO. Rather, both are served by a third-party supplier.
- c. Currently, RECO has no additional data centers projected within its service territory for the next three years.